



MUNICIPAL CORPORATION CHANDIGARH

Public Health Laboratory at Water Works Sector - 39

TEST - REPORT

Not for legal use

Ref. No. & Date :- No.DPS44/MC/01/24-25 dated :-26.11.2024
Issued to :- The Principal
:- Divya Public School
:- Sector - 44,D, Chandigarh
Quantity of sample :- Approximate 1200 ml
Date of Collection :- 21-12-2024
Client reference :- Sample Collected by Laboratory Staff.
Packing of sample :- Sample filled in P.P. and Glass Bottle.
Source of sample :- from School Tap of Divya Public School
Sector - 44,D, Chandigarh


S.No.	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	----	7.78
2	Odour	Agreeable	----	Agreeable
3	Taste	Agreeable	----	Agreeable
4	Turbidity	< 1.0	N.T.U.	0.8
5	Residual Chlorine	0.2 - 0.4	mg/l	0.2
6	Total Alkalinity (as CaCO ₃)	< 200	mg/l	80
7	Total Hardness (as CaCO ₃)	< 200	mg/l	68
8	Chloride (as Cl)	< 250	mg/l	04
9	Free & Saline Ammonia	NIL	mg/l.	NIL
10	Total Dissolved Solids	< 500	mg/l	117
11	M.P.N. of Coliform Bacilli Per 100ml of water	Zero	M.P.N.	0 (Excellent)


Payment received vide receipt No.12/2024-25/225807, dated 20.12.2024, Amount Rs.3300/-

Note: Water is fit for drinking.

Lab No.- MCPHL/24/ 4966

Dated:- 24.12.2024



Chemist
M.C.P.H. Laboratory
Chandigarh



Sub Divisional Engineer,
M.C.P.H. Sub Division No.1
Chandigarh

Endst No. MCPH/24/.....

Dated :-24.12.2024

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh
For Information Please.


Chemist
M.C.P.H. Laboratory
Chandigarh


Sub Divisional Engineer,
M.C.P.H. Sub Division No.1
Chandigarh