

No. ST/1740

Dated: 14-10-2025

TO WHOM IT MAY CONCERN

It is certified that I have visited the school building of “*Divya Public School, Sector 44-D, Chandigarh (U.T.)*” on 14/10/2025. The inspection was carried out along with the *Principal Mr. Rajesh Kamal*.

The School building has been constructed as a Framed Structure Building (i.e. Combination of RCC Columns and Beams) upto Basement + two storeys. The building was constructed in phased manner since year 2004 as per old codal provisions. The Plot area of the building is 5344 Sqm (approx.) and the combined covered area of all floors is approx. 1627 Sqm as per the plans produced by the Principal.

On the visual inspection there were no major structural/deflection cracks observed. Minor cracks had appeared on the Junction of RCC Slab and brickwork, which the management was intimated. Rebound hammer tests and Ultrasonic pulse velocity was also carried out to determine the strength of concrete.

As on date the building is fit for running an educational institute, provided it is properly maintained and retrofitted. The validity of this certificate is one year.

For M/s Continental Foundations




1 **STRUCTURAL STABILITY CERTIFICATE**

Approved Structural Consultants : ★ CPWD ★ Chandigarh Administration ★ Haryana Roads & Bridges Corp. Ltd.

★ Haryana Police Housing Corp. Ltd. ★ HSCC ★ Panjab University, Chandigarh ★ Panchayati Raj Dept. (Punjab)

Approved Valuers For : ★ Income Tax Deptt. (GOI) ★ PNB (Punjab) ★ UCO Bank

★ HDFC ★ Chd. House Fed. ★ Haryana Police Housing Co-op Ltd.



**PICTURES OF "DIVYA PUBLIC SCHOOL, SECTOR 44-D,
CHANDIGARH (U.T.)"**

2 **STRUCTURAL STABILITY CERTIFICATE**

